

MATCH EXISTING ASPHALT PAVEMENT AND ASPHALT TYPE

OR,  
50mm COMPACTED DEPTH, SIZE 10mm BITUMINOUS CONCRETE  
WHICHEVER IS GREATER

EXISTING SURFACE  
EMULSION SEAL  
FINISHED SURFACE

EMULSION SEAL

20mm CLASS 3 CRUSHED ROCK COMPACTED TO 95% AASHO, IN 150mm DEPTH LAYERS

20mm NOM. SIZE CLASS 2 CRUSHED ROCK, COMPACTED TO 98% AASHO IN 150mm DEPTH LAYERS

20mm CLASS 2 CRUSHED ROCK FOR PIPE BEDDING, MIN. DEPTH 50mm

D + 300 (MIN)

PIPES LAID IN SEALED ROADWAY AND DRIVEWAYS

EXISTING SURFACE  
FINISHED SURFACE

20mm CLASS 3 CRUSHED ROCK COMPACTED TO 95% AASHO, IN 150mm DEPTH LAYERS

20mm CLASS 2 CRUSHED ROCK FOR PIPE BEDDING, MIN. DEPTH 50mm

D + 300 (MIN)

PIPES LAID IN GRAVEL ROADWAY AND DRIVEWAYS

EXISTING SURFACE  
FINISHED SURFACE

50mm SELECTED LOAM

OTHER CLEAN EXCAVATED MATERIAL THOROUGHLY COMPACTED IN 150mm LAYERS TO THE DENSITY OF THE ADJACENT SOIL

BEST OF EXCAVATED MATERIAL COMPACTED TO 95% AASHO, IN 150mm LAYERS

HAUNCH BEDDING TO 50mm OVER TOP OF PVC PIPE OR TO SPRINGLINE FOR R.C. AND F.R.C. PIPES

20mm CLASS 3 CRUSHED ROCK COMPACTED TO 95% AASHO, IN 150mm DEPTH LAYERS

20mm CLASS 3 CRUSHED ROCK FOR PIPE BEDDING, MIN. DEPTH 50mm

D + 300 (MIN)

PIPES LAID IN NATURE STRIPS AND PRIVATE PROPERTY

NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS STATED OTHERWISE
2. REFER TO SHIRE OF YARRA RANGES SPECIFICATIONS FOR CIVIL WORKS FOR MINIMUM COVER OVER PIPES

AMENDMENTS

ORIGINAL - WDA

NOTES

UPDATED NOTES & DETAILS

DATE

8/97

10/2/99

1/07



PIPE BEDDING & BACKFILLING REQUIREMENTS

MANAGER CIVIL DEVELOPMENT SERVICES

*Handwritten signature*

DRAWN BY: WDA

DATE: JAN '07

SCALE: N.T.S.

DRAWING NO.:

SD / D2